

Test Certification

May 11, 2007

Japan Spinners Inspecting Foundation

1-18-15 Uemachi, Chuo, Osaka 540-0005 Japan

Phone: 06-6762-5887 -- Osaka

Fax: 06-6762-8588 -- Osaka

To: Dynic Corporation

Please find the following test results to the soil sample that were given to us.

Access Date: Apr 27, 2007

Product Description: Antibacterial, antiviral, anti-mold and anti-allergen filter

Quantity: one

[Testing Category]

Mold Test (Halo test)

[Testing Strain]

Aspergillus niger ATCC 6275

Penicillium citrinum ATCC 9849

Cladosporium cladosporioides NBRC 6348

[Testing Method]

The sample was adhered on a inoculated plate with the test bacterium, and after culturing at 27 degrees (± 1 degree) for 7 days, then, the width of a transparent growth inhibition zone (halo) around the sample was measured.

[Results]

Sample	Strain	Width of halo(mm)	
		4 days	7 days
Antibacterial, antiviral, anti-mold and anti-allergen filter	Aspergillus	5.0	3.8
	Penicillium	13.0	13.0
	Cladosporium	24.0	21.6

Test number 003488-3

The test result is subject only to the soil samples given to us and does not represent the consignment.